

REQUEST FOR INFORMATION

BERNCO, INC.
20816 ELEVEN MILE ROAD, SUITE 202
ST. CLAIR SHORES, MI 48081
(586) 445-3700 (586) 445-3701 FAX

R.F.I. NO. 5
PROJECT NO.

DATE: September 13, 2022

TO: Macomb County

RE: Macomb County Jail Various Project Proposal A, B & C

ATTN: Denise Mentzer

FROM: Tony Cattivera

PHONE #:

NO. OF PAGES, INCLUDING THIS SHEET: 1

Email: denise.mentzer@macombgov.org

COMMENTS: Please provide clarifications for the following items.

Item #1: The Mesh Contractor is requiring 240 Volt with a 40 Amp Breaker for the Welding Equipment that is required at each floor. Is the required power available at each floor? Secondly is the responsibility of the General Contractor to provide or will this additional work be performed on a Time and Material Bases?

ANSWER:

Contractor to Supply 240Volt to Tower, Based on time and Material Bases

Domenic Guadagnino 9-19-2022