

WAKELY ASSOCIATES, INC.
ARCHITECTS
30500 Van Dyke Avenue Suite 209
Warren, Michigan 48093

ADDENDUM NO. FOUR
MACOMB COUNTY JAIL
VARIOUS PROJECTS
PROPOSAL A, B AND C
Page 1 of 1 (write up only)

September 20, 2022

ADDENDUM NO. FOUR to the plans and specifications for the MACOMB COUNTY JAIL, VARIOUS PROJECTS PROPOSAL A, B AND C, MT. CLEMENS, MI, Architect's Project No. 221958, dated August 26, 2022

The above plans and specifications are modified, supplemented or augmented as follows, and this ADDENDUM NO. FOUR, is hereby made a part of the contract documents.

No Drawings are being issued with this Addendum.

PROPOSAL A

ARCHITECTURAL SPECIFICATION ITEMS

ITEM NO. 1: Refer to Specification Section 07810 "Applied Fireproofing" (not reissued):

1. Add Carboline to list of manufacturers for intumescent coatings.

ITEM NO. 2: Change intumescent coating on metal deck at Men's Locker Room to a cementitious coating to meet UL P741. Intumescent coating will remain on exposed secondary and primary steel members in that area. Cementitious coating may be by Carboline or Isolotek.

END OF ADDENDUM NO. 04

Cc: Denise Mentzer, Macomb County
Benjamin Treppa, Macomb County
Ron Syme, Wakely Associates
Domenic Guadagnino, Wakely Associates
Nate Stalker, SES
Paul Avolio, SES